

TEST CERTIFICATE

Certificate number: TC-J0096

Client: Liang Chew Hardware Pte Ltd
133 Kitchener Road
Singapore 208517

Product: Ductile Iron Heavy Duty Airtight & Watertight
Manhole Cover & Frame

Brand / Model: Norika / DIMCATD400-0600


Detail: Clear Opening (mm): 600 x 600, Grade A1

Specification: SS EN 124-2: 2021 } Dimensional Measurements
SS 30: 1999 (2012) } Compressive Load Test
BS 9124: 2008 } Water Ingress Test
Air Tightness Test

Test Report: 2423885/04-OWD, 21702333-MBM, 1920306/01-
OYC

Summary

A sample of product submitted was tested and found to comply with the test requirements of the above standard(s)


Head, Certification
Singapore Test Lab Pte Ltd

Date of Original Issue:

16 August 2019

Date of Last Revision:

17 June 2025

Date of Expiry:

15 August 2027

This Certificate is part of the listed full report(s) and should be read in conjunction with it. This Certificate remains the property of Singapore Test Lab Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the Terms and Conditions of Singapore Test Lab Pte Ltd.



Singapore Test Lab is an ISO / IEC 17065 Certification Body

Singapore Test Lab Pte Ltd. 10B Enterprise Road, Singapore 629828. Telephone: 6353 6393 Fax: 6353 6395

